

Johnson County Commission

William H. Gabel

Presiding Commissioner

Scott Sader

Commissioner, Eastern District

Destry Hough

Commissioner, Western District

Diane Thompson

County Clerk

Johnson County Courthouse, 300 N Holden, Warrensburg, MO 64093 (660) 747-6161 - Fax 747-9332 countyclerk@jococourthouse.com www.jococourthouse.com

March 4, 2013

INVITATION TO BID:

The Johnson County Commission is requesting bids for clear span fabric cover for use by the Road and Bridge Department.

Bid specifications may be obtained by contacting the Johnson County Clerk's Office, 300 N. Holden St, Warrensburg, MO, 64093, by telephone at (660) 747-6161 or by visiting the county's website at www.jococourthouse.com/Bids.htm.

Sealed bids will be accepted in the County Clerk's Office no later than 9:30 a.m., Thursday, March 21, 2013, at which time bids will be opened in the Commissioner's Office. The words "Clear Span Cover" must be clearly marked on the outside of the envelope containing said bid.

The County Commission reserves the right to reject any and/or all bids and may select the bid which they determine to be most advantageous.

JOHNSON COUNTY COMMISSION

William H. Gabel, Presiding Commissioner

Scott Sader, Eastern Commissioner

Destry Hough, Western Commissioner

Clear Span Fabric Cover Specifications

Size: 60'width x 100' or 65width' x 100'

Door at one end measuring 18' x 18', remainder of building will be constructed out of same fabric; other end of building open

Winch type door opener

Fabric must be 12.5 oz. 23 mil rip stop, U V Resistant color white

Trusses spaced 16' interval for 20# snow load 90mph wind

Price must include delivery

All tubing shall follow the specifications below:

- 1. Clear span structural steel tubing ASTM A500/ASTM A513
- 2. Minimum allowable tubing thickness 14 gauge or .083"
- 3. Minimum 50 KSI Yield 55 KSI Atensile ASTM A500
- 4. End wall framework engineered cold formed "C", "Z" and "L"
- 5. Minimum allowable thickness, 14 gauge or .083"
- 6. Engineered cold formed sections must be ordered to minimize splices and connections
- 7. End wall framework galvanized sheet G-90 material
- 8. Plate or bar stock ASTM A36
- 9. Bolts, Nuts and wasters ASTM A 325
- 10. All A325 connections must use a retaining compound
- 11. All bolts, anchors, cables and accessories to be made from galvanized steel